

MRC 'Secret Fix' Profile Compressed Faced Insulated Roof System with the option of R-Values of 0.9 / 1.2 m².K/W

Metal Profiled / Flat Sheet Cladding / Covering

DRAFT SPECIFICATION

Ref: Specification No. **xxxxxx/xx (Project Name & Location)**

To be read with Preliminaries/General conditions

Please note the following important notes:-

1. Any flexible bulk density faced insulation compressed between the roof sheet clip and the purlin thicker than 75mm is NOT advised to be used with the MRC 'Secret Fix' Roof System.
2. Insulation compressed between the roof sheet clip and the purlin will lose up to 40% of the stated uncompressed R-Value.

*Delete as necessary

120 METAL ROOF SYSTEM:

MRC 'Secret Fix' Profile Compressed Insulation System incorporating Guardian Warranty.

Warranty: Guardian System Warranty INCLUDING design, materials, workmanship and maintenance for up to 20 years.

(All equivalent warranty systems to provide an all encompassing warranty INCLUDING matching the material product guarantee with a workmanship warranty for the same term.)

Datasheet Reference: [MRC 'Secret Fix' Compressed Insulation System Ref No. MRC/FR/SF/IR/001](#)

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Profile Reference: MRC 'Secret Fix' Roofing System

Profile Dimensions: 41/233/700

Material: Aluminium zinc coated steel.

Aluminium coated Coating: AZ150 – Inland / non-corrosive conditions

Guarantee of the coating of the aluminium zinc coated steel to be requested depending on the location of the project.

Thickness/Gauge: 0.55mm (A certificate verifying material compliance including coating and gauge, shall be issued by the manufacturer.)

External finish/colour: ZincAL Mill Finish

Accessories:

- Straining wire insulation support system to suit R-Value and thermal insulation.
- MRC 'Secret Fix' Metal Profile Serrated Closures.
- MRC 'Secret Fix' Profile Polyethylene Closures Ridges, Penetrations & Headwalls.

MRC 'Secret Fix' Profile Compressed Faced Insulated Roof System with the option of R-Values of 0.9 / 1.2 m².K/W

Metal Profiled / Flat Sheet Cladding / Covering

Spacer System:	MRC 'Secret Fix' Clip, Straining wire insulation support system.
Fasteners:	MRC 'Secret Fix' Clip fixed to purlin using 3 number Class 4 Ashfix steel self-driller with wafer head per clip, all as per Structural Engineer's design. Fastener to be supplied with accredited third party test results confirming compliance with Australian Standard AS 3566.2-2002 & South African Standard SANS 1273-2011.
Optional Thermal Insulation:	R-Value (0.9 / 1.2) m ² .K/W as clause 271
Straining Wire Support:	As clause in conjunction with clause 266
Pitch:	≥ 2 degree minimum if perimeter details and penetrations are correctly formed.
Supports:	Light gauge galvanised steel purlins
Intermediate supports:	Subject to MRC 'Secret Fix' load/span charts.
Eaves / ridge overhang:	125-300mm from centre of 'Secret Fix' clip.
Side laps:	Interlocking side ribs with associated clips.
Experienced Contractors:	All contractors to be experienced in installing MRC 'Secret Fix' Roof Systems backed with 'Guardian' System Warranty. All contractors must be member of the Green Building Council SA, Master Builders Association & a level 4 BBEE contributor.

Other Requirements:

- MRC 'Secret Fix' Clips to be set out using the manufacturers setting out template.
- All penetrations to be installed correctly including polyclosures, mastics, sealants and tapes to ensure weather-tightness.
- All perimeter details and penetrations to be backed with the 'Guardian' System Warranty.
- MRC 'turn up' and 'turn down' tool to be used at the ridge / eaves.
- MRC 'Secret Fix' Roof sheeting to be supplied in single lengths i.e. ridge to eaves with no end laps.
- MRC Fabrications to be used for all flashings, weathered upstands, barge, sidewall, headwall flashings, soakers or specialised fabrications as all specified in all flashing clauses or as indicated on the drawings.
- Mobile On-site manufacturing of the MRC roof profile available.

160 'GUARDIAN' SYSTEM WARRANTY

Warranty Supplier:	MRC Group, Unit 6, Almar Centre, Crompton Street Pinetown, KZN, South Africa, KZN. Web: www.mrc-group.co.za Email: info@mrc-group.co.za
Reference:	'Guardian' System Warranty up to 20 years including design, materials, workmanship & maintenance.
Notes:	The 'Guardian' System Warranty is a warranty covering design, specified materials and perimeter details, workmanship and maintenance of a roofing and /or cladding installation.

Metal Profiled / Flat Sheet Cladding / Covering

The roofing contractor is to read all tender drawings in conjunction with the specification and should ensure that he is complying with the design intent, specification & drawings of the building designer.

GENERAL REQUIREMENTS

170 Design:

Complete the design of the cladding system in accordance with manufacturers recommendations & guidelines and co-ordinate detailed design with that of all related works. Submit detailed design proposals to the client's architect before commencing any cladding fabrication work.

172 Thermal Performance / Bridging:

Requirement: Complete thermal design of the cladding/covering system to minimise thermal bridging.

175 Product Samples:

Before commencing detailed design provide the clients' architects with identified samples of the Roofing System to obtain approval before proceeding.

176 Fastener Samples:

When submitting detailed design, provide the clients' architects with identified samples of each type of fastener.

DESIGN / PERFORMANCE REQUIREMENTS

180 Generally:

Requirements specified in this section unless indicated otherwise, apply to the whole roofing system including incorporated metal cladding, flashings and abutments with associated sealants, tapes & fasteners. Full allowance must be made for deflections and other forms of movement.

185 Verification of Performance:

Submit evidence and calculations demonstrating compliance of the design with performance requirements (thermal, acoustic, structural) before commencing fabrication of any part of the roofing. Reports, certificates and calculations must be based on approved laboratory testing or computer modelling.

187 Deflection of Metal Cladding:

Maximum permitted roof cladding deflection under distributed loads as a multiple of span and due to:

Cladding serviceability L/750 based on residual deflection SANS10237 for both dead and wind loads.

192 Sound Transmittance of Metal Profiled / Covering System:

Should thermal insulation be installed in conjunction with the 'Secret Fix' roof sheeting a minimum weighted sound reduction index (R_w) within 100 to 3150 Hz frequency range: 40 dB/other. Location: Through roof.

Metal Profiled / Flat Sheet Cladding / Covering

194 Internal Sound Absorption of Metal Profiled / Covering System:

Minimum sound absorption coefficients (a_s) : N/A
One third octave band centre frequency (Hz) : N/A

195 Integrity of Metal Profiled / Covering System:

Determine profile(s), size(s) and thickness(es) of sheets, the size(s), number and spacing of fixings, configuration and location of support spacer systems and incorporation of other accessories and fittings to ensure the roofing system will resist all dead, imposed and design live loads, and accommodate all deflections and thermal movements without damage.

198 Water Penetration:

Underside exposure conditions, moisture must not penetrate onto internal surfaces or into cavities not designed to be wetted. Therefore length and gauge of flashings, use of tapes and sealants are to be considered, to ensure long term weather-tightness.

FIXING CLADDING

202 Avoidance of Surface Condensation:

Requirement: Determine surface condensation risk of cladding/ covering system. Ensure that damage and nuisance from surface condensation does not occur.

210 Structure:

Check that structure is in a suitable state to receive cladding before commencing fixing. Roofing Contractor must confirm acceptance to Clients Architects and Structural Engineer.

210 Structural tolerances:

Purlin Bearing width: To Structural Engineers' Details, min 65mm.
Purlin Spacing: To Structural Engineers' Details

220 Structure:

Do not fix cladding until final coats of paint have been applied to outer surfaces of supporting structure.

217 Protection:

Store metal sheets and panels under cover to keep dry and prevent staining. Pack to be stored at an angle to allow trapped water to drain. Limit height of stacks to avoid distortion. Adequately secure stored sheets/panels to prevent wind and mechanical damage.

219 Fastenings Generally:

Flashings, liner, spacer and clip fixings, type(s), size(s), material(s) and finish(es) as specified, or in the absence of such specification, as recommended for the purpose by the roof system manufacturer.

System Supplier:

MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Metal Profiled / Flat Sheet Cladding / Covering

221 Fittings and Accessories Generally:

Cappings, closure pieces, flashings, fabrications, trims, sills, gutters, fillers, spacers, tapes, sealants, fixings etc, where not specified to be types recommended by roof system manufacturer and/or indicated on the project drawings.

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

230 Isolating Tapes:

A type recommended for the purpose by roof system manufacturer. Apply to those surfaces of supports, which would otherwise be in contact with cladding or accessories after fixing.

234 Rainwater Goods if required:

Gutters and downpipes, with associated finishes, joints, fixings and brackets to suit project requirements.

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

234 Valley Gutters:

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Material: To suit span and site conditions.
Gauge/Thickness: To suit the girth and size of the gutter.
Size: In accordance with Latest Building Regulations.
Insulation: N/A
Gutter joints: C/w cross linked butyl mastic sealant and associated fixings.
All details to ensure water-tightness.
Rainwater pipes: To suit drainage requirements.

235 Lightweight Eaves Gutters:

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Material: To suit span and site conditions.
Gauge/Thickness: To suit the girth and size of the gutter.
Size: In accordance with Latest Building Regulations.
Insulation: N/A
Gutter joints: C/w cross linked butyl mastic sealant and associated fixings.
All details to ensure water-tightness.
Rainwater pipes: To suit drainage requirements.

MRC 'Secret Fix' Profile Compressed Faced Insulated Roof System with the option of R-Values of 0.9 / 1.2 m².K/W

Metal Profiled / Flat Sheet Cladding / Covering

266 Straining Wire Support:

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Thickness / Material: Minimum 1.6mm thick coated galvanised steel.
Support Centres: Between 300 – 400mm

271 Optional Insulation:

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

Type: Flexible Faced Glasswool Tested to SANS 10177 Part 5, Non-combustible with an inert binder.
Facing: (Foil / White / Black / Coloured)
Thickness: (50 / 75 mm) to suit (0.9 / 1.2) compressed R-Value.
Thermal conductivity: $\lambda=0.040\text{W/m.K}$
Installation: Install and secure as the work proceeds, ensuring continuity between and under purlin spacers and supports and over ridges / hips, pack tightly leaving no gaps. Keep dry.

300 Profile Fillers:

Type(s): Supplied by the roof system manufacturer accurately matching the roof sheet system profiles.
Material: Closed Cell Expanded Polyethylene Polyclosures.
Location: Locate where shown on drawings and wherever necessary to close off corrugation cavities from the outside of the building. Ensure a tight fit, sealed with 8mm diameter sealer tape and leave no gaps. Provide purpose made raking cut filler blocks to each side of hips/valleys.

310 Purpose made Cold Formed Metal Accessories:

System Supplier: MRC Group, Unit 6, Almar Centre, Crompton Street
Pinetown, KZN, South Africa, KZN.
Web: www.mrc-group.co.za
Email: info@mrc-group.co.za

All these details are backed with the 'Guardian' System Warranty including design, materials, workmanship and maintenance.

All details to include tapes, sealants and fixings to ensure weather tightness, as per the MRC technical bulletins on the MRC Website – [Technical Bulletins](#) & [Technical Drawings](#).

Detail: Headwall

MRC Technical Bulletin Ref: Generally as MRC/FR/SF/PDHW/IR/001.
Drawing reference(s): Generally as MRC/FR/SF/PDHW/IR/DWG001.
Material: To match the specified roof system.

MRC 'Secret Fix' Profile Compressed Faced Insulated Roof System with the option of R-Values of 0.9 / 1.2 m².K/W

Metal Profiled / Flat Sheet Cladding / Covering

Thickness/gauge:	Minimum 0.8mm
Finish/Colour:	To match the specified roof system.
Sealants:	8mm diameter self-adhesive butyl tape or impregnated polyurethane foam sealing strip.
Polyclosure:	Closed Cell Polyethylene

Detail: Sidewall

MRC Technical Bulletin Ref:	Generally as MRC/FR/SF/PDSW/IR/001.
Drawing reference(s):	Generally as MRC/FR/SF/PDSW/IR/DWG002.
Material:	To match the specified roof system.
Thickness/gauge:	Minimum 0.55mm
Finish/Colour:	To match the specified roof system.
Sealants:	8mm diameter self-adhesive butyl tape or impregnated polyurethane foam sealing strip.
Polyclosure:	Closed Cell Polyethylene

Detail: Ridge

MRC Technical Bulletin Ref:	Generally as MRC/FR/SF/PDR/IR/001.
Drawing reference(s):	Generally as MRC/FR/SF/PDR/IR/DWG003.
Material:	To match the specified roof system.
Thickness/gauge:	Minimum 0.8mm
Finish/Colour:	To match the specified roof system.
Sealants:	8mm diameter self-adhesive butyl tape or impregnated polyurethane foam sealing strip.
Polyclosure:	Closed Cell Polyethylene

Detail: Eaves

MRC Technical Bulletin Ref:	Generally as MRC/FR/SF/PDE/IR/001.
Drawing reference(s):	Generally as MRC/FR/SF/PDE/IR/DWG006.
Material:	To match the specified roof system.
Thickness/gauge:	Minimum 0.55mm
Finish/Colour:	To match the specified roof system.

Detail: Barge

MRC Technical Bulletin Ref:	Generally as MRC/FR/SF/PDB/IR/001.
Drawing reference(s):	Generally as MRC/FR/SF/PDB/IR/DWG004.
Material:	To match the specified roof system.
Thickness/gauge:	Minimum 0.55mm
Finish/Colour:	To match the specified roof system.
Sealants:	8mm diameter self-adhesive butyl tape or impregnated polyurethane foam sealing strip.
Polyclosure:	Closed Cell Polyethylene

Metal Profiled / Flat Sheet Cladding / Covering

Detail: Penetration

MRC Technical Bulletin Ref:	Generally as MRC/FR/SF/PDHW/IR/001.
Drawing reference(s):	Generally as MRC/FR/SF/PDHW/IR/DWG001.
Material:	To match the specified roof system.
Thickness/gauge:	Minimum 0.8mm
Finish/Colour:	To match the specified roof system.
Sealants:	8mm diameter self-adhesive butyl tape or impregnated polyurethane foam sealing strip.
Polyclosure:	Closed Cell Polyethylene

410 Cutting and Drilling Sheets Generally:

On no account should abrasive wheel cutting methods be adopted. Cut sheets to give clean, true lines with no distortion. Remove burrs and any lubricant and apply a coating to the cut ends.

Remove all drilling swarf, dust and any other foreign matter before finally fixing sheets into position. Protect sheets adequately during fixing and up to practical completion against mechanical damage, corrosion and disfigurement. Rectify any defects as quickly as practicable to minimise damage and nuisance.

460 Thermal Movement:

Accommodated within the design of the system. A fixed point is required.

Note:

Draft Specification for MRC 'Secret Fix' Roof Systems.

The purpose of this Draft Specification is to assist the Project Designer and Quantity Surveyor in producing their respective documentation for any project under consideration.

It is provided in good faith for use at the discretion of the respective consultant, to be amended and edited as required to suit the particular project requirements.

MRC Systems (PTY) Ltd is not privy to detailed contractual arrangements and documentation of an individual project and are therefore not in a position to co-ordinate related work by others. It is not the intention for this draft to relate to any particularly project but to provide a guide to the more common items to be encountered in MRC 'Secret Fix' systems.

Whilst it is the Project Designer/Quantity Surveyors/Planning Supervisor's responsibility to produce their respective documents and we can assist them in their duties, we cannot accept responsibility for any errors or omissions which may occur in tender or contract documents or for compliance with the requirements of Health and Safety/Construction Design and Management Regulations which may be applicable.

Please check to ensure that any amendments to the standard draft, represents a true interpretation of the Project Designer's requirements.

Metal Profiled / Flat Sheet Cladding / Covering

DISCLAIMER

All rights reserved - No part of this document, process or information shared as a consequence of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise without the prior written consent of MRC Group. Specifically, the content, structure, format, analysis, design, methodology and models derived as a consequence of this proposal remain the property of MRC Group. The document is prepared solely for and is intended for the exclusive use of those to whom it has initially been issued and will not become public knowledge until approved by MRC Group.